


GB300



Belt expansion joint on duct angles with pre-insulation, without arch

Design: Straight or conical elastomer or multilayer expansion joint

with sleeve for clamp bar fixing

Optional expansion joint with installation seam

Installation method: Clamp bar fixing on duct angles

Dimensions: For round and rectangular duct cross sections

Installation length: = Installation gap + 2x fixing width

Individually according to customer specifications

Fixing width: Depends on pressure and nominal diameter between

60 and 100 mm

Media temperature: Depending on the material, height of the duct elbow and

duct lining, suitable for up to $1,200^{\circ}$

Pressure: Up to ± 0.25 bar

Higher pressures on request

Movement: For axial, lateral and angular movements

Benchmarks:

axial compression = approx. 0.20 x installation gap axial extension = approx. 0.20 x installation gap lateral displacement = approx. 0.15 x installation gap In the event of axial extension and simultaneous lateral

displacement, movements are reduced

For large lateral movements, we recommend presetting

the duct against the direction of movement

Application:

Power plants, waste incineration plants, gas turbines, cement factories, paper industry, steel industry e.g. in exhaust pipes, in ventilators, in air ducts, in ash lines, in filter systems



Expansion joints

	Multilayer expansion joint
Temperature:	Depending on the duct angle height and lining, up to 1200°C
Design:	Multilayer fabric expansion joint consisting of interior insulating layers, embedded sealing films and exterior pressure carrier fabrics.
Material:	Internal layers: PTFE glass fibre fabric laminate, glass fibre fabric, glass mat, silicate fabric
	Sealing films: PTFE film, stainless steel film
	External layer: Silicon coated glass fibre fabric, PTFE-glass fibre fabric laminate

Pre-insulation

Design: Insulation layers, cut to the installation gap, consisting of heat-resistant wire mesh

Insulation layers made from glass, ceramic, silicate or mineral wool Optional installation-ready, fabric-sheathed insulation pillow Duct lining necessary for high medium temperatures

Clamp bar

Design: Multi-part clamp bar with slotted holes

Materials: Carbon steel: 1.0038 (S235JRG2)

Stainless steel: 1.4301 (X5CrNi18-10)

1.4571 (X6CrNiMoTi17-12-2)

Other materials on request

Coating: Primed, hot-dip galvanised, special paint

Optional accessories

Fixing: Screws, nuts, washers,

disc springs

Installation unit: Installation-ready installation

unit complete with premounted expansion joint, flow liner and connecting ends for welding or screwing into the duct (▶ page 299)

Installation set: Tools and aids for punching

and closing the expansion

joint seam

